TURBINE FLOWMETER USER'S MANUAL

HP-228
January 2007

HOFFER FLOW CONTROLS, INC.
The Turbine Flowmeter Company

107 Kitty Hawk Lane, P.O. Box 2145, Elizabeth City, NC 27906-2145
800-628-4584 252-331-1997 FAX 252-331-2886
www.hofferflow.com E-mail: info@hofferflow.com

NOTICE

Hoffer Flow Controls, Inc. makes no warranty of any kind with regard to this material, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose.

This manual has been provided as an aid in installing, connecting, calibrating, operating, and servicing this unit. Every precaution for accuracy has been taken in the preparation of this manual; however, Hoffer Flow Controls, Inc. neither assumes responsibility for any omissions or errors that may appear nor assumes liability for any damages that result from the use of the products in accordance with information contained in the manual.

HOFFER FLOW CONTROLS' policy is to provide a user manual for each item supplied. Therefore, all applicable user manuals should be examined before attempting to install or otherwise connect a number of related subsystems.

During installation, care must be taken to select the correct interconnecting wiring drawing. The choice of an incorrect connection drawing may result in damage to the system and/or one of the components.

Please review the complete model number of each item to be connected and locate the appropriate manual(s) and/or drawing(s). Identify all model numbers exactly before making any connections. A number of options and accessories may be added to the main instrument, which are not shown on the basic user wiring. Consult the appropriate option or accessory user manual before connecting it to the system. In many cases, a system wiring drawing is available and may be requested from Hoffer Flow Controls.

This document contains proprietary information, which is protected by copyright. All rights are reserved. No part of this document may be photocopied, reproduced, or translated to another language without the prior written consent of Hoffer Flow Controls, Inc.

HOFFER FLOW CONTROLS' policy is to make running changes, not model changes, whenever an improvement is possible. This affords our customers the latest in technology and engineering. The information contained in this document is subject to change without notice.

THIS WARRANTY IS EXPRESSLY IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. HFC SHALL NOT BE LIABLE FOR ANY LOSS OR DAMAGE RESULTING, DIRECTLY OR INDIRECTLY, FROM THE USE OR LOSS OF USE OF THE GOODS. WITHOUT LIMITING THE GENERALITY OF THE FOREGOING, THIS EXCLUSION FROM LIABILITY EMBRACES THE PURCHASER'S EXPENSES FOR DOWNTIME OR FOR MAKING UP DOWNTIME, DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, DAMAGES TO PROPERTY, AND INJURY TO OR DEATH OF ANY PERSONS. HFC NEITHER ASSUMES NOR AUTHORIZES ANY PERSON TO ASSUME FOR IT ANY OTHER LIABILITY IN CONNECTION WITH THE SALE OR USE OF HFC'S GOODS, AND THERE ARE NO ORAL AGREEMENTS OR WARRANTIES COLLATERAL TO OR AFFECTING THE AGREEMENT. *PURCHASER'S SOLE AND EXCLUSIVE REMEDY IS THE REPAIR AND/OR REPLACEMENT OF NONCONFORMING GOODS AS PROVIDED IN THE PRECEDING PARAGRAPHS. HFC SHALL NOT BE LIABLE FOR ANY OTHER DAMAGES WHATSOEVER INCLUDING INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES.*

LIMITED WARRANTY POLICY FOR HOFFER FLOW CONTROLS

HOFFER FLOW CONTROLS, INC. ("HFC") warrants HFC's Precision Series and API Series of turbine flowmeters to be free from defects in material and workmanship under normal use and service, only if such goods have been properly selected for the service intended, properly installed and properly operated and maintained as described in the turbine flowmeter manual. Reference "turbine flowmeter manual" for specific details. This warranty shall extend for a period of five (5) years from the date of shipment to the original purchaser and covers the Precision Series and API Series of flowmeters supplied with their standard hybrid ceramic ball bearings only. All other HFC products carry a one (1) year warranty. This warranty is extended only to the original purchaser ("Purchaser"). *Purchaser's sole and exclusive remedy is the repair and/or replacement of nonconforming goods as provided in the following paragraphs.*

In the event Purchaser believes the Hoffer product is defective, the product must be returned to HFC, transportation prepaid by Purchaser, within the appropriate warranty period relative to the product. If HFC's inspection determines that the workmanship or materials are defective and the required maintenance has been performed and, has been properly installed and operated, the product will be either repaired or replaced, at HFC's sole determination, free of additional charge, and the goods will be returned, transportation paid by HFC, using a transportation method selected by HFC.

Prior to returning the product to HFC, Purchaser must obtain a Returned Material Authorization (RMA) Number from HFC's Customer Service Department within 30 days after discovery of a purported breach of warranty, but not later than the warranty period; otherwise, such claims shall be deemed waived. See the Return Requests/inquiries Section of this manual.

If HFC's inspection reveals the Hoffer product to be free of defects in material and workmanship or such inspection reveals the goods were improperly used, improperly installed, and/or improperly selected for service intended, HFC will notify the purchaser in writing and will deliver the goods back to Purchaser upon receipt of Purchaser's written instructions and agreement to pay the cost of transportation. If Purchaser does not respond within thirty (30) days after notice from HFC, the goods will be disposed of in HFC's discretion.

HFC does not warrant the product to meet the requirements of any safety code of any state, municipality, or other jurisdiction, and Purchaser assumes all risk and liability whatsoever resulting from the use thereof, whether used singlely or in combination with other machines or apparatus.

This warranty shall not apply to any HFC product or parts thereof, which have been repaired outside HFC's factory or altered in any way, or have been subject to misuse, negligence, or accident, or have not been operated in accordance with HFC's printed instructions or have been operated under conditions more severe than, or otherwise exceeding, those set forth in the specifications.

FOR **NON-WARRANTY** REPAIRS OR **CALIBRATIONS**, consult HOFFER FLOW CONTROLS for current repair/calibration charges. Have the following information available BEFORE contacting HOFFER FLOW CONTROLS:

1. P.O. number to cover the COST of the repair/calibration,
2. Model and serial number of the product, and
3. Repair instructions and/or specific problems relative to the product.

TURBINE FLOWMETER INSTALLATION AND SERVICE MANUAL

TABLE OF CONTENTS

WARRANTY PERIOD LISTED BY PRODUCT 1
TURBINE FLOWMETER INSTALLATION AND SERVICE MANUAL 2
INTRODUCTION 2
PRINCIPLE OF TURBINE FLOWMETER OPERATION 2
MATERIAL SELECTION AND CONSTRUCTION 2
BEARING SELECTION 3
FLOWMETER PICKUP SELECTION 3
FLOWMETER CALIBRATIONS 5
GENERAL INSTALLATION PROCEDURE 6
STRAINERS/FILTERS 8
FLOW STRAIGHTENERS and INSTALLATION KITS 9
SIGNAL CABLES 10
SIGNAL CONDITIONERS/CONVERTERS 10
PREVENTIVE MAINTENANCE AND TROUBLE SHOOTING 11
PICKUP COIL TESTING 11
BEARING REPLACEMENT 11
BEARING REPLACEMENT for THREADED SHAFTS 12
BEARING REPLACEMENT for NON-THREADED SHAFTS 13
EXPLODED VIEW/TURBINE INTERNALS 14
PICKUP COILS, SPARE & REPLACEMENTS 15
RECOMMENDED SPARE AND REPLACEMENT PARTS 16
STORAGE OF THE TURBINE FLOWMETER 17
APPENDIX A – HAZARD ANALYSIS 18
APPENDIX B – DRAWINGS 21

WARRANTY PERIOD LISTED BY PRODUCT

5 Year Limited Warranty

API Precision HO Series – Excluding pickup coils
Liquid Precision HO Series – Excluding pickup coils
Gas Precision HO Series – Excluding pickup coils

1 Year Limited Warranty		
Type	**Series**	**Service**
3A	HO	Liquid
Star/Industrial	HO	Liquid
Teflon	HO	Liquid
Mini-Flowmeter	MF	Liquid & Gas
Insertion	HP	Liquid & Gas
Wing Nut*	HO	Liquid
Grooved	HO	Liquid
PD Meters	HOG	Liquid
OEM	Lo-Co	Liquid
Pickup Coils	All	
Signal Conditioners, Converters & Electronic Accessories	All	
Flowstar & Nova-Flow Series Flow Computers	All	
ACE & ACE II	All	
Digital & Analog Totalizers/Rate Indicators.		
Electronic Spares/Cables & Replacement parts.		
All outside purchased items such as: Valves, Strainers, Pressure & Temperature Transmitters.		

***Note**:* *Turbine flowmeters are ideally suited for service in clean liquid and gas service. Certain Hoffer turbine flowmeter series may be enhanced for use in slurry type flow applications. The flowmeter internals will eventually wear when the turbine flowmeter is installed in a "dirty" type of flow application. The rate of wear is a function of flow velocity, the type of slurry service, and the percentage of particulate to liquid. HFC is unable to predict the life of the flowmeter internals for slurry applications. Our standard product warranty does not apply for flowmeters that will be used in slurry type applications.*

TURBINE FLOWMETER INSTALLATION AND SERVICE MANUAL

INTRODUCTION

We are proud that you have selected a Hoffer Turbine Flowmeter, the finest precision turbine flow transducer on the market.

The Hoffer Turbine Flowmeter has been designed, constructed, and selected for your application with care by a qualified staff of professional engineers, technicians, and sales personnel.

We welcome you to our growing family of satisfied customers. If you are not completely satisfied with either our product or service, we encourage you to let us know. We want to improve!

The following information is provided for the proper installation and maintenance of your instrument.

PRINCIPLE OF TURBINE FLOWMETER OPERATION

The flowmeter is a volumetric measuring turbine type.

The flowing fluid engages the vaned rotor causing it to rotate at an angular velocity proportional to the fluid flow rate.

The angular velocity of the rotor results in the generation of an electrical signal (AC sine wave type) in the pickup. The summation of the pulsing electrical signal is related directly to total flow. The frequency of the signal relates directly to flow rate.

The vaned rotor is the only moving part of the flowmeter.

MATERIAL SELECTION AND CONSTRUCTION

Hoffer Turbine Flowmeters are available in a broad range of standard and special materials. The wide range of construction options allows for the selection of the optimum combination of useful range, corrosion resistance, and operating life for a particular application. A low mass rotor design allows for rapid dynamic response which permits the turbine flowmeter to be used in pulsating flow applications. The deflector cones eliminate downstream thrust on the rotor and allows for hydrodynamic positioning of the rotor between deflector cones.

The hydrodynamic positioning of the low mass rotor provides wider rangeability and longer bearing life than that of conventional turbine flowmeters. Integral flow straightening tubes minimize the effects of upstream flow turbulence.

The housing is made of nonmagnetic materials. The rotor is made of magnetic or magnetized material. Bearings are chosen based on service fluid, cost, and accuracy considerations.

Standard materials of construction are 316 stainless steel for the flowmeter body and rotor supports. The rotor materials of construction include 17.4 pH SS, NICKEL 200 and 430 SS. Many special materials are available for meter construction, some of which include teflon, 4130 steel, monel, other grades of stainless steel, hastalloy, titanium, tantalum, and numerous other exotic materials.

Selection of the materials of construction is usually dictated by requirements of media compatibility, availability, and cost considerations.

The materials supplied in your flowmeter have been selected for the best service of your application.

BEARING SELECTION

Numerous bearing types are available including ball bearings and sleeve type construction in tungsten carbide, Teflon, and carbon graphite composite.

When selecting among several chemically compatible bearings, the ball bearing design offers the highest accuracy and generally will have the widest usable range. It remains the bearing of choice in many fluids and is required for gas flowmeters.

Tungsten carbide bearings offer the most durable bearing material for service fluids in which it is compatible. These represent the standard bearing type for many industrial service environments.

Teflon and carbon graphite composite bearings offer properties which are nearly chemically inert to many corrosive fluids and are utilized primarily for this reason.

In turbine flowmeters, the flowing fluid provides the bearing lubrication in most applications. It may be observed that fluids which offer a high natural lubricity tend to prolong the life of the flowmeter. Many bearing types offer advantages in that they provide self-lubrications as well as providing a wear resistant surface. Among these bearing materials are carbon graphite composites, teflon, and some ball bearing designs.

Bearing life has been found to be approximately inversely proportional to the square of the bearing speed. To prolong the life of the flowmeter, it is therefore advantageous to operate the flowmeter at rates less than the maximum flowrate. For example, if the flowmeter is operated at 1/3 of the maximum flowrate, it will wear at approximately 1/10 the rate.

The bearings in your flowmeter have been selected by our staff based on what we have found to be the best choice for your application.

FLOWMETER PICKUP SELECTION

The flowmeter pickup senses the motion of the rotor and converts it to a pulsing electrical signal which is of a discrete, digital nature.

Hoffer Flow Controls offers several pickup types suited for different applications. The advantages of each are listed.

HIGH OUTPUT MAGNETIC PICKUP - TYPICAL RANGE 10:1

The standard pickup for turbine flowmeters larger than 1 inch produces a high level sinusoidal output. To produce this, the pickup generates a relatively high magnetic field. The signal may be transmitted up to 200 feet without amplification. A flow range of 10:1 or better is common with this pickup type.

LOW DRAG MAGNETIC PICKUP - TYPICAL RANGE 25:1

Low drag magnetic pickups may be used to obtain a flowmeter range of 25:1 or better. They offer a significant reduction in drag effects with lower output levels and may require pre-amplification prior to transmission. Low drag magnetic pickups are used extensively in meter sizes below 1 inch.

MAGNETIC PICKUP OUTPUT SIGNAL CHARACTERISTICS

The output signal voltage of the magnetic coil is approximately sinusoidal. The frequency range of the pulsing signal varies from meter size to meter size. However, standard ranges allow for maximum output frequencies at the nominal linear flow of 250, 500, 750, 1000, 1500, 2000, and 2500 Hz.

The amplitude of the output signal is a function of flowrate. The voltage at the minimum linear flow is greater than 30 millivolts peak to peak when measured into a 10,000 ohm load.

On larger size flowmeters the output level may exceed several volts peak to peak. The DC output resistance of the magnetic pickup coil is generally less than 2,000 ohms. Detailed impedance characteristics are available on request.

MODULATED CARRIER PICKUP (MCP) - TYPICAL RANGE 100:1

The Hoffer MCP pickup is an active coil which eliminates pickup drag and requires a Modulated Carrier Signal Conditioner be mounted on or near (10 feet or less) the flowmeter. The MCP works on a principle where the motion of the rotor modulates a high frequency signal. The conditioner demodulates, filters, amplifies, and shapes the resulting signal prior to transmitting it as a high level signal. Use of the MCP pickup allows for wider flow ranges than can be achieved with low drag magnetic pickups. The cost compares with that of a preamplifier for a magnetic pickup. This pickup type is used extensively when a wide flow range is required or with flowmeters that are being used with a universal viscosity calibration curve (UVC). Typically, MCP coils can obtain flowmeter ranges of up to 100:1.

QUADRATURE OUTPUT OPTION

When a Hoffer Turbine Flowmeter is equipped with two pickup coils properly positioned on the flowmeter housing, it is possible to sense flow direction, flowrate and total flow as well as add/subtract options.

The pickup coils generate two output signals with a quadrature (90º) phase difference. With suitable electronic phase discriminating circuitry, it is possible to provide two separate output signals, one of which is related to flow in the forward direction only, with the second relating to flow in the reverse direction only.

Hoffer Turbine Flowmeters, unlike many other turbines, are built physically symmetrical which inherently makes bi-directional flow measurement possible with only the addition of a second pickup coil, keeping cost considerably less than other manufacturers. Other considerations which may dictate equipping two pickup coils on a single flowmeter arise from advantages in the ease of achieving parallel signal processing or increased reliability.

HAZARDOUS AND WEATHERPROOF ENVIRONMENTAL COIL ENCLOSURES

The explosion proof requirements of UL Class I, Group C and D, Class II, and NEMA 4X are routinely provided for by enclosing the pickup coil in a suitable housing. Signal conditioners and converters can readily be mounted on the flowmeter. Hoffer Turbine Flowmeters are inherently safer since they require no through holes eliminating the possibility of a leak.

FLOWMETER CALIBRATIONS

The standard calibration provided with most Hoffer Turbine Flowmeters consists of a 10-point water calibration over the linear flow range of the meter. A number of optional flowmeter calibrations may also be requested.

A 10-point water calibration over the extended range of the meter may be requested at no additional charge. Additional calibration points may be requested within the linear range or in the extended range at additional cost.

Fluids other than water are used to simulate viscosity conditions from 2 to 300 centistokes. Where it is necessary to document flowmeter performance for viscous service, the flowmeter calibration simulates the viscosity, as well as, the flow rate anticipated in actual service.

Universal Viscosity Calibration (UVC) curves may be documented for each Hoffer Turbine Flowmeter where this information is required to achieve maximum flowmeter accuracy in medium to high viscosity service.

In general, any flowmeter size may be supplied with a UVC. However, since smaller meter sizes (under one inch) display the largest sensitivity of calibration factor to viscosity, it is this size range which is the most likely to be considered for a UVC.

The UVC may be utilized to determine the K-Factor either graphically, or in the case of an intelligent instrument, algorithmically, for a measured set of flowing conditions.

Hoffer offers a standard viscosity calibration which consists of ten repeated points for each viscosity required. A typical UVC curve requires three sets of ten points plotted as a continuous curve. In addition, Hoffer offers a ten point single viscosity (up to 300 centistokes) calibration at a nominal additional fee.

GENERAL INSTALLATION PROCEDURE

Upon receipt of the turbine flowmeter a visual inspection should be performed checking for any indications of damage which may have occurred during shipment. Inspect all packing material carefully to prevent the loss of meter parts or auxiliary components which may have been packed with the shipment. Refer to the packing list/invoice for a detailed list of items included in the shipment.

The meter housing is marked by a flow direction arrow and the inlet is marked 'IN' and the outlet is marked 'OUT'. The meter must be installed in the piping in the correct orientation to ensure the most accurate and reliable operation. Care should be taken in the proper selection of the mating fittings. Size, type of material, and pressure rating should be the same as the flowmeter supplied. The correct gaskets and bolts should be utilized.

The flowmeter may be installed horizontally or vertically for liquid service without affecting the meter calibration, however, in gas applications the meter must be installed horizontally for proper operation. When it is expected that flow will be intermittent, the meter should not be mounted at a low point in the piping system. Solids which settle or congeal in the meter may affect meter performance.

In order to achieve optimum electrical signal output from the flowmeter, due consideration must be given to its isolation from ambient electrical interference such as nearby motors, transformers, and solenoids.

GENERAL PIPING CONSIDERATION

As stated in the Principle of Flowmeter Operation, the fluid moving through the flowmeter engages the vaned rotor. Swirl present in the fluid ahead of the meter can change the effective angle of engagement and, therefore, cause a deviation from the supplied calibration (performed under controlled flow conditions). Turbine meters are constructed with flow straighteners to minimize the affects of fluid swirl and non-uniform velocity profiles is adequate for most installations. However, it is good practice to maintain a minimum straight run of pipe approximately 10 pipe diameters ahead of the inlet and 5 pipe diameters following the outlet. Proper installation of the flowmeter minimizes the negative effects of fluid swirl.

A typical flowmeter installation is shown below:



Figure 1 Typical Flowmeter Installation

Blocking and Bypass valves should be installed if it is necessary to do preventive maintenance on the flowmeter without shutting down the flow system. The Bypass valve can be opened before the Blocking valves allowing the flow to continue while removing the turbine flowmeter for service.

IMPORTANT:	*All flow lines should be purged prior to installing the meter. To prevent possible damage to the meter, install the meter* ***ONLY*** *in flow lines that are clean and free of debris.*

Upon initial start-up of the system a spool piece should be installed in place of the flowmeter so that purging of the system can be performed to remove all particle debris which could cause damage to the meter internals. In applications where meter flushing is required after meter service, care should be taken as to not over-speed the meter, as severe meter damage may occur.

CAUTION:	*Avoid over-spinning the meter. Over-spinning the meter may cause damage to the meter internals and lead to needless meter failure.*

To maintain an accurate flow measurement it is necessary to maintain a downstream pressure sufficient to prevent flashing/cavitation. Flashing of the liquid will result in an indication of flow significantly higher than the actual flow. In order to eliminate this condition adequate downstream pressure must be maintained. The minimum required downstream pressure may be calculated using the following equation:

$$\text{MinimumPressure} = (2 \times \text{PressureDrop}) + (1.25 \times \text{VaporPressure})$$

Downstream pressure may be maintained by a downstream valve that provides the necessary downstream pressure to prevent flashing/cavitation in the metering run.

STRAINERS/FILTERS

Turbine flowmeters are designed for use in a clean fluid service. However, the service fluid may carry some particulate material which would need to be removed before reaching the flowmeter. Under these conditions a strainer/filter may be required to reduce the potential hazard of fouling or damage that may be caused by foreign matter. Strainer/filters are recommended to be used with the Hoffer Mini-Flow Series meters.

METER SIZE	MESH SIZE	PARTICLE SIZE (Maximum)
MF Series	100	.0055
¼" to ½"	100	.0055
$^{5}/_{8}$" to 1¼"	70	.008
1½" to 3"	40	.015
4" to 12"	24	.028

If a strainer/filter is required in the system, it should be located upstream of the flowmeter taking care that the proper minimum distance is kept between the strainer and flowmeter.

FLOW STRAIGHTENERS and INSTALLATION KITS

FLOW STRAIGHTENING

Proper application of the Hoffer Turbine Flowmeter requires a suitable piping section to achieve optimum accuracy. While an inlet straight pipe run of 10 pipe diameters and an outlet straight pipe run of 5 pipe diameters provide the necessary flow conditioning in general, some applications require an upstream flow straightener. This consists of a section of piping that contains a suitably dimensioned and positioned thin walled tube cluster to eliminate fluid swirl.



Figure 2 Typical Flow Straightener

A typical application requiring a flow straightener would be custody transfer.

Flanged flow straightening sections are available from ½" to 12" line sizes with mating fittings in pressure ratings from 150# to 2500# ratings. Beveled type end fittings for welding are also available.

MS INSTALLATION KITS

Installation kits for the MS end fittings consist of two lengths of stainless steel tubing cut to a length appropriate for the upstream and downstream straight pipe run and flared at one end. Mating sleeves and nuts are included. The kits may be conveniently butt welded into the user's piping. Alternately the kits may be provided with NPT or flanged connections to facilitate installation of smaller flowmeters into larger existing lines. This adapted form of the installation kit is recommended for use with the Hoffer Mini Flowmeters since only MS end fittings are offered in the Mini Flow Series.

Flow straightening sections may be provided within the installation kit.

MS installation kits are available in turbine sizes from ¼" to 2".

SIGNAL CABLES

Two conductor shielded cabling recommended for the Hoffer Turbine Flowmeter is generally available in most industrial settings. However, Hoffer stocks cabling for user convenience. Cabling is available cut to length with dressed end connections. Recommended cable is Beldon 8422 or equal.

SIGNAL CONDITIONERS/CONVERTERS

Consideration should be given to properly interface the turbine flowmeter output to the host electronics. If the system is installed in an electrically noisy area or if the distance from the turbine flowmeter to the host electronics exceeds 500 feet a signal conditioner may be necessary.

Hoffer Signal Conditioners for the turbine flowmeter provide amplification, filtering, and wave shaping of the low level flowmeter pickup signal and generate a high level pulse output signal suitable for transmission to a remote host system through a noisy environment.

Several output forms (i.e., TTL/CMOS, open collector, etc.) are available to suit various interface requirements. The conditioned pulse output signal may be transmitted several thousand feet.

Note:	*The standard (1) year warranty applies to all coils, signal conditioners/converters and Hoffer electronics.*

PREVENTIVE MAINTENANCE AND TROUBLE SHOOTING

PICKUP COIL TESTING

Testing the MAG and MCP (RF) coils consists of measuring the resistance with an ohmmeter.

1. Measure the resistance between pin A and pin B. The resistance should be approximately as listed in the following table.
2. The resistance from any pin to the case should be greater than 1 megohm.

Table A - DC Resistance of some common coils*

COIL	DC RESISTANCE (Ohms)
MC2PAHT	15.0 ±10%
MCP	2.5 ±10%
MCP3A	11.5 ±10%
PC13-110G	1800 ±10%
PC13-70G	1800 ±10%
PC13-74G	1800 ±10%
PC13-74S	1850 ±15%
PC24-45G	1350 ±10%
PC24-45S	1850 ±15%
PC28-13G	120 ±20%
PC28-14G	180 ±20%

If either resistance measurement fails, replace the pickup coil. Firmly seat the new coil in the flowmeter.

BEARING REPLACEMENT

The type of bearings installed in the flowmeter have been selected to operate in the type of service being metered.

It is recommended that the bearings be checked periodically for wear. The type of fluid being measured, as well as temperature and cleanliness of the service, have a direct relationship on the life expectancy of the bearings. Therefore, it is best to contact the engineering department or the HFC Customer Service department for the proper preventive maintenance interval.

It is recommended that the bearings be replaced if any signs of wear are apparent. An unexplained shift in the output accuracy could be a sign of worn bearings.

* For specific coils not listed contact the HFC Customer Service Department for the approximate resistance readings.

CAUTION:	*If bearings are allowed to operate without replacement at the recommended interval, the accuracy of the device may drift from the original calibration and if left long enough severe damage to the rotor and/or internals may occur.*

Ball bearings can be changed in the field. Sleeve type bearings can not be changed in the field. If no down time can be tolerated, a spare rotor with sleeve bearing or complete set of spare internals should be stocked.



Figure 3 Exploded View – Flowmeter Internals

BEARING REPLACEMENT FOR THREADED SHAFTS

1. Remove the meter to a clean stable work surface.
2. Using two “Spin-Tite” wrenches, remove one lock nut from the shaft.
3. Place a small head stove bolt in a vise. Guide the bolt head gently through one of the hanger/flow straightener tubes and in a smooth firm stroke remove the hanger from the housing.
4. With the shaft placed vertically downward, carefully remove a cone, two bearings, and the rotor.
5. Remove the other hanger in a similar manner.
6. Examine the shaft and cones for scoring. If scoring is present, replacement is necessary.
7. Obtain new bearings of the same type from stock or the manufacturer. Discard old bearings.
8. Reassemble one hanger in the housing with the shaft, a cone, and an end nut.
9. Place the bearings into the rotor. Guide the bearings and rotor onto the shaft making sure to reassemble with the “IN” side of rotor facing the “IN” side of the housing.
10. Place the remaining cone on the shaft. Gently “rattle” the flowmeter to seat the internals on the shaft.
11. When properly seated, gently push the hanger onto the shaft. Be sure to properly align the hanger on the shaft. The hangers seat against a shoulder machined into the housing.

12. Gently tighten the self-locking lock nuts until they make contact with the spring clip hanger. “Two Finger” tight on a “Spin-Tite” is more than adequate.
13. Holding the meter horizontally, gently blow into it (DO NOT use compressed air). The rotor should turn freely. With a magnetic coil the rotor should gradually slow down and then “quiver” to a stop with one of its blades aligning with the pickup coil. With a MCP (RF) coil the rotor should “coast” smoothly to a stop.
14. Clean the flowmeter assembly with ISOPROPYL ALCOHOL or an alternately approved cleaning solution.

The flowmeter is ready for service. When installing the flowmeter be sure to orientate the input and output correctly.

BEARING REPLACEMENT FOR NON-THREADED SHAFTS

1. Remove meter to a clean stable work surface.
2. Insert the hanger tool (3P-Tool HFC Stock # 300-8113) into the hanger/flow straightener assembly.
3. Turn the P3-Tool until the hanger tubes are aligned with the scallops in the meter housing.
4. Holding the meter in the vertical direction slowly remove the tool. The hanger, shaft, cones, rotor, and bearings should come out with the tool. Should any of the components hang-up inside the meter housing care should be taken in their removal.
5. Remove the remaining hanger in a similar manner.
6. Examine the shaft and cones for scoring. If scoring is present, replacement is necessary.
7. Obtain new bearings of the same type from stock or the manufacturer. Discard old bearings.
8. Insert the shaft with cone into the hanger and assemble the remaining internal parts onto the shaft.
9. Place the hanger assembly with the internals on the P3-Tool.
10. Hold the housing in the vertical position and align the hanger assembly with the scallops in the meter housing.
11. Gently slide the hanger and rotor assembly into the housing with the “IN” on the rotor oriented in the same direction as the “IN” on the housing.
12. When the hanger assembly is fully inserted into the meter housing, twist the P3-Tool to secure the hanger in the ‘locked’ position.
13. Align the second hanger with the scallops on the housing and with the rotor shaft.

***Caution*:** *It is very important that the shaft is properly inserted into the second hanger. Failure to do so will result in damage to the rotor, shaft, and/or bearings.*

14. With the hanger properly positioned in the housing, secure it in place by inserting the P3-Tool and twisting it to the 'locked' position.
15. Using the P3-Tool align the tubes of the two hangers.
16. Holding the meter horizontally, gently blow into it (DO NOT use compressed air). The rotor should turn freely. With a magnetic coil the rotor should gradually slow down and then "quiver" to a stop with one of its blades aligning with the pickup coil. With a MCP (RF) coil the rotor should "coast" smoothly to a stop.
17. Clean the flowmeter assembly with ISOPROPYL ALCOHOL or an alternately approved cleaning solution.

The flowmeter is ready for service. When installing the flowmeter be sure to orientate the input and output correctly.

EXPLODEDVIEW/TURBINE INTERNALS



HO SERIES CALIBRATED SPARE OR REPLACEMENT INTERNAL KITS



MODEL -__ - __ - __ - __ - Internals

Flowmeter Size

Minimum Flow Range

Maximum Flow Range

Bearing Type

CB - Ceramic Hybrid self-lubricating ball bearings.
T - Tungsten Carbide
TFE - Teflon
C - Hard Carbon Composite

SPARE OR REPLACEMENT PICKUP COILS

PART NO. RATING	DESCRIPTION OF SERVICE	TEMPERATURE
MC3PAE	RF Coil ½" MNPT & 3" Leads	-325º to +325ºF
MC3PA	RF Coil All HO Series	-325º to +325ºF
PC13-110G	Cryogenic HO1 & Up	-450º to +450ºF
PC13-74G	WECO HO 2X2 & HO 3X3 Liquid & Navy	-450º to +450ºF
PC13-74S	HO Series HO1 & Up & Mini-Flows	-450º to +450ºF
PC24-45G	HO1/4 thru HO3/4 Cryogenic, Trident & SY100	-450º to +450ºF
PC24-45S	HO1/4 thru HO3/4 & HO1 & Larger Gas	-450º to +450ºF
PC24-45EX	HO1/4 thru HO3/4 & HO1 & Larger Gas with ½" MNPT & 3" Leads	-450º to +450ºF
PC28-13G	High Temp High Drag	-450º to +850ºF
PC3-24G	Reluctance Center Mag for All Teflon	-35º to +120ºF
PC24-92G	Hydrogen Vacuum Jacket	-450º to +450ºF
PC28-14G	High Temp Low Drag	-450º to +850ºF
PC3-24EX	Reluctance Teflon Series with ½" MNPT & 3" Leads	-35º to +120ºF
MC2PAHT	High Temp RF with 3' Leads	-450º to +450ºF
MC2PA	High Temp 2 Pin RF	-150º to +330ºF
PC13-108G	Cryogenic 1" & Larger	-450º to +450ºF
PC24-113G	WECO HO2X1 & HO2X11/2 Liquid & Gas	-450º to +450ºF
PC13-74EX	Hi Drag with ½" MNPT & 3" Leads	-450º to +450ºF
PC13-74S	Cryogenic 1" & Larger	-450º to +450ºF
RF-4	WECO's All Sizes Requiring RF	-325º to +325ºF
ISM-001	Intrinsic Mag Hi Drag 1" & Up & Mini-Flow Use	-97º to +207ºF
PC24-123G	WECO HO2X2 & HO3X3 Gas	-450º to +450ºF
ISM-003	Intrinsic Mag Low Drag ¾" & Smaller Use	-97º to +207ºF
ISM-006	Intrinsic Reluctance For All Teflon Use	-35º to +120ºF
PC28-38G	Hi Temp/Hi Drag For WECO HO2X11/2 & HO2X1	-450º to +850ºF
PC3-33G	Reluctance Teflon Hi Output	-35º to +120ºF
HE01S	Hall Effect Coil For HOG	-40º to +302ºF
M-L3/8X1.52	Lo-Co Coil	-50º to +250ºF
REDI-PULSE PICKUP COILS:		
RPMxxx	Redi-Pulse Mag Coil	-40º to +185ºF
RPRxxx	Redi-Pulse RF Coil	-40º to +185ºF
DMXxxx	Redi-Pulse Intrinsically Safe Mag Coil	-40º to +185ºF
DRXxxx	Redi-Pulse Intrinsically Safe RF Coil	-40º to +185ºF

NOTE: For the complete part number of the Redi-Pulse Pickup Coils or Intrinsically Safe Redi-Pulse Pickup Coils, Consult Factory.

RECOMMENDED SPARE AND REPLACEMENT PARTS

To assure maximum operating efficiency and minimum down time it is recommended that the following parts be stocked at all times.

Part*	Nomenclature	Qty.
Pickup Coil	Pickup Coil	1
Bearings	Ball Bearing type only	1 (set)
Rotor Assembly	Rotor with sleeve bearing	1
Complete Calibrated Internals Kit	Assembled & calibrated meter internals consisting of rotor, shaft, cones, bearings, and hangers.	1

NOTE: *Recommended spare parts lists should not be construed as an indication of possible failure, but reflect material available only from the manufacturer or his authorized representative. Quantity of recommended spares is based upon a single unit at any given location and provisioning may be adjusted accordingly in the event that multiple units comprise a system.*

* Contact the HFC Customer Service Department with the equipment model and serial number for the part numbers and current pricing for recommend spare parts.

STORAGE OF THE TURBINE FLOWMETER

The internal components of the turbine flowmeter are precision components which must be handled with care, and therefore, only qualified personnel should service the flowmeter.

Industrial Applications

When a turbine meter is removed from the process fluid to be placed in storage, the following preventative actions should be taken in order to prevent bearing failure:

For corrosive or non-lubricating fluids (excluding cryogenic and gas meters).

1. Clean all components with alcohol and allow to dry completely.
2. Coat all parts with machine oil.

For lubricating fluids.

1. Coat all parts with machine oil.

No abrasive material, such as emery paper or crocus cloth, should be used to clean any of the internal parts of the flowmeter.

After the flowmeter is properly cleaned and coated with oil, the end fittings should be covered with end caps so that no foreign material can enter the meter while in storage.

Cryogenic Application

In cryogenic applications, if the turbine flowmeter is removed from service and placed in storage, the meter must first be disassembled in a clean area. The area should be free from dust, oil, moisture, organic/inorganic particles, and any other pollutants which could contaminate the flowmeter components. Follow the procedures for bearing replacement as previously discussed.

Reassemble the flowmeter (after installing new bearings and replacing any worn parts). Next, the flowmeter should be immersed and thoroughly washed in an approved solvent. Take care to remove any oils or other contaminants present. At the conclusion of the solvent wash, allow the flowmeter to air dry.

The cleaned flowmeter should be placed in a plastic bag and electrically sealed for storage. The flowmeter is then tagged as "Cleaned for Cryogenic Service".

Sanitary Applications

When a sanitary turbine flowmeter is removed from service and placed in storage, the meter must first be cleaned by the recommended 3-A cleaning specifications. The flowmeter should then be allowed to thoroughly dry before storing. Once the meter is thoroughly dry, cap the end fittings so that no particles can enter the meter. Place the meter in a sealed plastic bag for storage.

When placing the sanitary meter back into service, remove the meter from the sealed bag and remove the protective caps. Clean the flowmeter as required by 3-A cleaning specifications before placing meter in service.

APPENDIX A

Hazard Analysis for Flow Meters and Installation Kits

Hoffer flow meters and installation kits are manufactured using PED compliant materials (if required) and are designed to operate under the specified applications and the temperature and pressure conditions.

Hazard Identification

The following hazards associated with operating Hoffer flow meters has been identified.

Type of Hazard	*Hazard Classification For Applications With Dangerous Fluids (Group 1)*	*Hazard Classification For Applications With Non-Dangerous Fluids (Group 2)*
Pipe/Meter Bursting	Dangerous Risk	Dangerous Risk
Flange Leaking	Dangerous Risk	Residual Risk
Skalds Risk	Residual Risk	Residual Risk

Risk Evaluation

Exceeding MAWP

The meters are design to withstand specified maximum allowable working pressure (MAWP) and temperature. The MAWP is listed on the meter drawing supplied with the meter. Under no circumstances shall fluid pressure exceed the MAWP. If the MAWP is exceeded, there is a dangerous risk of the meter or pipe bursting. In particularly, a meter could explode in pieces and flying metal debris could cause death or injury to the operator. In addition, there could be a burst of fluid contained in the meter. Fluids from Group 1 can cause fire, explosion, death or injury. Fluids from Group 2 can cause flooding, damage to the nearby equipment and short circuits in the electrical installations.

Flange Leaking

Hoffer flow meters should be installed according to the Hoffer Flow user manual. Proper fittings and washer should be used when applicable. Flanges should be tightened to the specified torque. In case of a leak from a flange or coupling, fluids from Group 1 can cause fire, explosion, death or injury. Fluids from Group 2 can cause flooding, damage to the nearby equipment and short circuits in the electrical installations.

Scalds Risk

There is a risk of skin scald in the applications where fluid operating temperatures are above 120 deg. F.

Vibration

Meters installed in vibrating pipes may develop weld defects and material cracks.

Corrosion

Meters shall be used only with corrosion compatible fluids.

Meter Internals Breakage

Meter internal parts may break when maximum allowable flow rate is exceeded.

Definition of Terms

Burst Pressure

Maximum pressure a pressure vessel can contain with out rupturing.

This is a calculated pressure using the Barlow's formula

(P = 2ST/D)

Where P = Burst pressure

S = Minimum material tensile strength at less than 40 deg. C

T = Minimum wall thickness

D = Outside diameter of vessel

Design Pressure

Maximum pressure above which the pressure vessel may sustain structural damage or fatigue. This is a calculated pressure using the Barlow's formula (P = 2ST/D)

When P = Maximum design pressure

S = Minimum material yield strength at less than 40 deg. C

T = Minimum wall thickness

D = Outside diameter of the vessel

Notes:

1. Design pressure can be de-rated for higher temperatures based on material yield strength at specified temperature.

2. Factors such as mechanical loads neither linear nor axial have been accounted for in these calculations.

Working Pressure

Pressure of the media contained in the system during normal operating conditions.

Maximum Allowable Working Pressure

The working pressure is recommended by Hoffer Flow Controls Inc.

The design pressure divided by a safety factor or a calculated pressure using Barrow's formula ($P = 2ST/D$).

When P = Maximum allowable working pressure
S = Minimum material stress at max temperature according too ASME B31.3

TABLE A-1

T = Minimum wall thickness

D = Outside diameter of pressure vessel

APPENDIX B

DRAWINGS

Related Drawings

For

Intrinsically Safe Pickup Coil

DWG NO.	500-0105	SH 1	REV C

REVISIONS

ZONE	REV	DESCRIPTION		DATE	APP
	A	REVISED NOTES PER CUSTOMER REQUIREMENTS.	(CS)	950821	JD
	B	ZNC3 CONNECTOR P/N WAS MS3106A14S-2P.	(CS)	950925	JD
	C	CORRECTED CONN. P/N.	(CS)	951004	JD

ENTITY PARAMETERS ON I.S. APPROVED MAGNETIC PICKUP COILS

Vmax = 30Vdc
Imax = 300mA
Ci = 0 uF
Li = 0 mH

HAZARDOUS LOCATION

NOTE 3



NON-HAZARDOUS LOCATION

I.S. BARRIER
NOTE 4, 5, 6

SAFE AREA EQUIPMENT

NOTES:

1. FOR CSA-NRTL INSTALLATIONS: INSTALLATION SHOULD BE IN ACCORDANCE WITH ANSI/ISA RP12.6 "INSTALLATION OF INTRINSICALLY SAFE SYSTEMS FOR HAZARDOUS LOCATIONS" AND THE NATIONAL ELECTRIC CODE (ANSI/NFPA 70).
2. FOR CSA INSTALLATIONS: INSTALL IN ACCORDANCE WITH CANADIAN ELECTRICAL CODE PART I.
3. PICKUP COILS EQUIPPED WITH THE "MS" TYPE CONNECTOR ARE ONLY SUITABLE FOR HAZARDOUS LOCATIONS CLASS I, DIV. 1,GROUPS A, B, C, D, CLASS II DIV. 1, GROUP G, CLASS III AND COAL DUST. PICKUP COILS EQUIPPED WITH A "NPT" CONNECTOR AND PIGTAIL LEADS CAN BE USED IN HAZARDOUS LOCATIONS CLASS I, DIVISION 1, GROUPS A, B, C, D, CLASS II, DIV.1, GROUPS E,F & G, CLASS III.
4. FOR ENTITY INSTALLATIONS, SELECT A CSA CERTIFIED BARRIER THAT SATISFIES THE FOLLOWING:

   $V_{max} \geq V_{oc}$ $\quad C_i + C_{cable} \leq C_a$
   $I_{max} \geq I_{sc}$ $\quad L_i + L_{cable} \leq L_a$

5. FOR SYSTEM INSTALLATIONS, USE A CSA CERTIFIED SINGLE CHANNEL BARRIER HAVING THE PARAMETERS OF 28Vdc (MAX), AND 300 OHMS (MIN).
6. BARRIERS MUST BE INSTALLED IN ACCORDANCE WITH MANUFACTURES INSTRUCTIONS.
7. Ex*ia* IS DEFINED AS INTRINSICALLY SAFE / SECURITE INTRINSEQUE.

CERTIFIÉ CONFORME

J.DEFEO
NAME
9/25/95
DATE

			DATE
DRAWN	SWEET		950812
CHECK	J.DEFEO		950815
PRODUCTION	M.K.VAUGHN		950815
PROJ ENG	J.DEFEO		950815

NEXT ASSY | USED ON

APPLICATION

CONFIDENTIAL PROPERTY OF HOFFER FLOW CONTROLS, INC. (HFC) NOT TO BE DISCLOSED TO OTHERS, REPRODUCED, OR USED FOR ANY OTHER PURPOSE, EXCEPT AS AUTHORIZED IN WRITING BY HFC. MUST BE RETURNED ON DEMAND, ON COMPLETION OF ORDER OR OTHER PURPOSE FOR WHICH LENT.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES OTHER THAN THE SIZE OF RAW MATERIAL SHALL BE HELD AS FOLLOWS:

2 PLACE DECIMALS	± .01
3 PLACE DECIMALS	± .005
FRACTIONAL	± 1/64
ANGULAR	± 1/2°

HOFFER FLOW CONTROLS, INC
ELIZABETH CITY, NC 27909

TITLE: INSTALLATION DRAWING, INTRINSICALLY SAFE PICKUP COIL ISM-XXX SERIES, CLASS I THRU VII

SIZE	CAGE CODE	DWG NO	REV
C	33321	500-0105	C

SCALE NONE | SHEET 1 OF 1

H:\DRAWINGS\500\5000105I.DWG

DWG NO.	500-0106	SH 1	REV A

REVISIONS

ZONE	REV	DESCRIPTION	DATE	APP
	A	ZNC3 CONNECTOR P/N WAS MS3106A10S-2P. (CS)	950925	

ENTITY PARAMETERS ON I.S. APPROVED MAGNETIC PICKUP COILS

Vmax =30Vdc
Imax = 300mA
Ci = 0 uF
Li = 1.2 mH

HAZARDOUS LOCATION

NOTE 3



NON-HAZARDOUS LOCATION

I.S. BARRIER
NOTE 4, 5, 6

SAFE AREA EQUIPMENT

NOTES:

1. FOR CSA-NRTL INSTALLATIONS: INSTALLATION SHOULD BE IN ACCORDANCE WITH ANSI/ISA RP12.6 "INSTALLATION OF INTRINSICALLY SAFE SYSTEMS FOR HAZARDOUS LOCATIONS" AND THE NATIONAL ELECTRIC CODE (ANSI/NFPA 70).
2. FOR CSA INSTALLATIONS: INSTALL IN ACCORDANCE WITH CANADIAN ELECTRICAL CODE PART I.
3. PICKUP COILS EQUIPPED WITH THE "MS" TYPE CONNECTOR ARE ONLY SUITABLE FOR HAZARDOUS LOCATIONS CLASS I, DIV. 1,GROUPS A, B, C, D, CLASS II DIV. I, GROUP G, CLASS III AND COAL DUST. PICKUP COILS EQUIPPED WITH A "NPT" CONNECTOR AND PIGTAIL LEADS CAN BE USED IN HAZARDOUS LOCATIONS CLASS I, DIVISION I, GROUPS A, B, C, D, CLASS II, DIV.1, GROUPS E,F & G, CLASS III.
4. FOR ENTITY INSTALLATIONS, SELECT A CSA CERTIFIED BARRIER THAT SATISFIES THE FOLLOWING:

   $V_{max} \geq V_{oc}$ $\quad C_i + C_{cable} \leq C_a$
   $I_{max} \geq I_{sc}$ $\quad L_i + L_{cable} \leq L_a$

5. FOR SYSTEM INSTALLATIONS, USE A CSA CERTIFIED SINGLE CHANNEL BARRIER HAVING THE PARAMETERS OF 28Vdc (MAX), AND 300 OHMS (MIN).
6. BARRIERS MUST BE INSTALLED IN ACCORDANCE WITH MANUFACTURES INSTRUCTIONS.
7. Ex*ia* IS DEFINED AS INTRINSICALLY SAFE / SECURITE INTRINSEQUE.

CERTIFIÉ CONFORME

NAME

9/25/95
DATE

DRAWN	SWEET	DATE	950821
CHECK	J.DEFEO		950822
PRODUCTION	M.K.VAUGHN		950822
PROJ ENG	J.DEFEO		950822

NEXT ASSY | USED ON

APPLICATION

CONFIDENTIAL PROPERTY OF HOFFER FLOW CONTROLS, INC. (HFC) NOT TO BE DISCLOSED TO OTHERS, REPRODUCED, OR USED FOR ANY OTHER PURPOSE, EXCEPT AS AUTHORIZED IN WRITING BY HFC. MUST BE RETURNED ON DEMAND, ON COMPLETION OF ORDER OR OTHER PURPOSE FOR WHICH LENT.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES OTHER THAN THE SIZE OF RAW MATERIAL SHALL BE HELD AS FOLLOWS:

2 PLACE DECIMALS	± .01
3 PLACE DECIMALS	± .005
FRACTIONAL	± 1/64
ANGULAR	± 1/2°

HOFFER FLOW CONTROLS, INC
ELIZABETH CITY, NC 27909

TITLE
INSTALLATION DRAWING, INTRINSICALLY SAFE PICKUP COIL ISMC-XXX SERIES, CLASS VIII

SIZE	CAGE CODE	DWG NO	REV
C	33321	500-0106	A

SCALE NONE | SHEET 1 OF 1

H:\DRAWINGS\500\50001061.DWG

Related Drawings

DWG NO.	HOX-5001	SH 1	REV F

REVISIONS

ZONE	REV	DESCRIPTION	DATE	APP
	F	FOR REVISIONS A-E, SEE REV E. DWG NO WAS 500-0157, REVISED TO SHOW NEW COUPLING PER ECP 335	971001	

NOTE:
REFER TO SHEET 2
FOR DIMENSIONS.



FRONT VIEW SIDE VIEW

X-PROOF VERSION
STYLE 3



SIDE VIEW FRONT VIEW SIDE VIEW OF 22B

X-PROOF VERSION
STYLE 4



FRONT VIEW SIDE VIEW

X-PROOF VERSION
GUAC



FRONT VIEW SIDE VIEW

STANDARD

REPLACES 500-0157

		MATERIAL	CONTRACT/JN	
			DRAWN DW	DATE 2-4-92
			CHECK JD	2-4-92
		FINISH	QA HC	2-4-92
			PROJ ENG KRH	2-4-92
NEXT ASSY	USED ON	CONFIDENTIAL PROPERTY OF HOFFER FLOW CONTROLS, INC. (HFC) NOT TO BE DISCLOSED TO OTHERS, REPRODUCED, OR USED FOR ANY OTHER PURPOSE, EXCEPT AS AUTHORIZED IN WRITING BY HFC. MUST BE RETURNED ON DEMAND, ON COMPLETION OF ORDER OR OTHER PURPOSE FOR WHICH LENT.	UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES, TOLERANCES OTHER THAN THE SIZE OF RAW MATERIAL SHALL BE HELD AS FOLLOWS: 2 PLACE DECIMALS ± .01 3 PLACE DECIMALS ± .005 FRACTIONAL ± 1/64 ANGULAR ± 1/2°	
APPLICATION				

HOFFER FLOW CONTROLS, INC
ELIZABETH CITY, NC 27909

TITLE: INSTALLATION DRAWING,
1/2" - 3" FLOWMETERS
STD & X-PROOF VERSIONS
MS33656 ENDS

SIZE	CAGE CODE	DWG NO	REV
C	33321	HOX-5001	F

SCALE NONE SHEET 1 OF 2

DWG NO.	HOX-5001	SH 2	REV F

REVISIONS

ZONE	REV	DESCRIPTION	DATE	APP

NOMINAL DIMENSIONS FOR FLOWMETERS WITH MS33656 ENDS

SIZE	A	B	C	D (MS33656)	E1	E2	E3	E4	F
1/4 – 1/2	2.45	1.225	1 1/8" HEX	3/4–16UNF–3A	12.00	11.00	6.812	2.375	.437
5/8	2.75	1.375	1 1/8" HEX	7/8–14UNF–3A	12.00	11.00	6.812	3.031	.500
3/4	3.25	1.625	1 3/8" HEX	1 1/16–12UNF–3A	12.00	11.00	6.937	3.156	.684
1	3.50	1.75	1 5/8" HEX	1 5/16–12UNF–3A	12.063	11.187	7.062	3.281	.898
1 1/4	3.87	1.937	1 7/8" HEX	1 5/8–12UNF–3A	12.187	11.313	7.187	3.406	1.176
1 1/2	4.38	2.187	2" HEX	1 7/8–12UNF–3A	12.25	11.375	7.25	3.468	1.37
2	4.75	2.375	2 3/4" HEX	2 1/2–12UNF–3A	12.625	11.75	7.625	3.843	1.75
2 1/2	6.06	3.03	3 1/4" HEX	3–12UNF–3A	12.875	12.00	7.875	4.093	2.488
3	7.50	3.75	3 3/4" HEX	3 1/2–12UNF–3A	13.125	12.25	8.125	4.343	2.964

REPLACES 500-0157

DRAWN	SIZE	CAGE CODE	DWG NO	REV
DW	C	33321	HOX-5001	F
CHECKED: JD	SCALE: NONE		SHEET: 2 OF 2	

DWG NO.	HOX-5005	SH 1	REV E

NOTE:
ALL SIZES UP TO AND INCLUDING 2" ARE BUILT WITH HEX BODIES; 2-1/2" AND UP ARE BUILT WITH ROUND BODIES.

REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APP
	A	REDRAWN FOR MORE DETAIL	12-12-90	
	B	PUT ON NEW HOFFER BORDER	2-6-92	
	C	CH'D TO REFLECT HEX MATERIAL.	4-2-92	
	D	DRAWING NO. WAS HOX-5005. (CS)	950816	KRH
	E	DWG NO WAS 500-0159, REVISED PER ECP335, REMOVED UNION AND ADDED COUPLING.	971001	



X-PROOF VERSION
STYLE 3



X-PROOF VERSION
GUAC



X-PROOF VERSION
STYLE 4



STANDARD

REPLACES 500-0159

		MATERIAL	DRAWN DW	DATE 2-6-92
			CHECK JD	2-6-92
			PRODUCTION	
		FINISH	PROJ ENG KRH	2-6-92
			MACH SHOP	
NEXT ASSY	USED ON	CONFIDENTIAL PROPERTY OF HOFFER FLOW CONTROLS, INC. (HFC) NOT TO BE DISCLOSED TO OTHERS, REPRODUCED, OR USED FOR ANY OTHER PURPOSE, EXCEPT AS AUTHORIZED IN WRITING BY HFC. MUST BE RETURNED ON DEMAND, ON COMPLETION OF ORDER OR OTHER PURPOSE FOR WHICH LENT.	UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES, TOLERANCES OTHER THAN THE SIZE OF RAW MATERIAL SHALL BE HELD AS FOLLOWS: 2 PLACE DECIMALS ± .01; 3 PLACE DECIMALS ± .005; FRACTIONAL ± 1/64; ANGULAR ± 1/2°	
APPLICATION				

HOFFER FLOW CONTROLS, INC
ELIZABETH CITY, NC 27909

TITLE: INSTALLATION DRAWING, 1/2" – 4" FLOWMETERS STD & X-PROOF VERSIONS N.P.T. ENDS

SIZE	CAGE CODE	DWG NO	REV
C	33321	HOX-5005	E

SCALE NONE SHEET 1 OF 2

DWG NO.	HOX-5005	SH 2	REV E

REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APP

NOMINAL DIMENSIONS FOR FLOWMETERS WITH N. P. T. ENDS

SIZE	A	B	** C	D (N. P. T. TAPERED)	E1	E2	E3	E4	F
1/4 THRU 1/2	2. 45	1. 225	1. 125	1/2 – 14	12. 00	11. 00	6. 812	2. 375	. 622
5/8	2. 75	1. 375	1. 125	3/4 – 14	12. 00	11. 00	6. 812	3. 031	. 824
3/4	3. 25	1. 625	1. 375	3/4 – 14	12. 00	11. 00	6. 937	3. 156	. 824
1	3. 50	1. 75	1. 625	1 – 11 1/2	12. 063	11. 187	7. 062	3. 281	1. 049
1 1/4	3. 875	1. 937	1. 875	1 1/4 – 11 1/2	12. 187	11. 313	7. 187	3. 406	1. 38
1 1/2	4. 375	2. 187	1. 875	1 1/2 – 11 1/2	12. 25	11. 375	7. 25	3. 468	1. 610
2	4. 75	2. 375	2. 750	2 – 11 1/2	12. 625	11. 75	7. 625	3. 843	2. 067
2 1/2	6. 062	3. 031	2. 882	2 1/2 – 8	12. 875	12. 00	7. 875	4. 093	2. 567
3	7. 50	3. 75	3. 50	3 – 8	13. 00	12. 125	8. 000	4. 218	3. 068
4	10. 00	5. 00	4. 75	4 – 8	12. 625	12. 75	8. 75	4. 968	4. 062

REPLACES 500-0159

DRAWN	DW	SIZE	CAGE CODE	DWG NO	REV
CHECKED	JD	C	33321	HOX-5005	E
		SCALE NONE		SHEET 2 OF 2	

DWG NO.	HOX-5002	SH 1	REV H

NOTES:

1. DIMENSIONS FOR 150lb FLANGES SEE SHEET 2 OF 6.
2. DIMENSIONS FOR 300lb FLANGES SEE SHEET 3 OF 6.
3. DIMENSIONS FOR 400 & 600lb FLANGES SEE SHEET 4 OF 6.
4. DIMENSIONS FOR 900 & 1500lb FLANGES SEE SHEET 5 OF 6.
5. DIMENSIONS FOR 2500lb FLANGES SEE SHEET 6 OF 6.

REVISIONS

ZONE	REV	DESCRIPTION	DATE	APP
	G	FOR REVISIONS A–F REF. REV F. DWG NO. WAS 500–0158. REVISED PER ECP335, REMOVED UNION AND ADDED COUPLING	971002	ES
	H	SHEET 5, CORRECTED 3" DIM. 'C', 'D' AND H	021206	



X–PROOF VERSION
STYLE 3



X–PROOF VERSION
STYLE 4



X–PROOF VERSION
GUAC



STANDARD

REPLACES 500–0158

MATERIAL	DRAWN	DW	DATE	HOFFER FLOW CONTROLS, INC ELIZABETH CITY, NC 27909
	CHECK	JD	2-6-92	
	QA	HC	2-6-92	
FINISH	PROJ ENG	KRH	2-6-92	
	MACH SHOP			

TITLE: INSTALLATION DRAWING, 1/2" THRU 12" FLOWMETER STD & X–PROOF VERSIONS FLANGED ENDS

SIZE	CAGE CODE	DWG NO	REV
C	33321	HOX–5002	H

SCALE NONE SHEET 1 OF 6

NEXT ASSY | USED ON

APPLICATION

CONFIDENTIAL PROPERTY OF HOFFER FLOW CONTROLS, INC. (HFC) NOT TO BE DISCLOSED TO OTHERS, REPRODUCED, OR USED FOR ANY OTHER PURPOSE, EXCEPT AS AUTHORIZED IN WRITING BY HFC. MUST BE RETURNED ON DEMAND, ON COMPLETION OF ORDER OR OTHER PURPOSE FOR WHICH LENT.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES OTHER THAN THE SIZE OF RAW MATERIAL SHALL BE HELD AS FOLLOWS:

2 PLACE DECIMALS	± .01
3 PLACE DECIMALS	± .005
FRACTIONAL	± 1/64
ANGULAR	± 1/2°

DWG NO.	HOX-5002	SH 2	REV H

REVISIONS

ZONE	REV	DESCRIPTION	DATE	APP

NOMINAL DIMENSIONS FOR FLOWMETERS WITH 150lb. FLANGES

SIZE	A	B	C	D	E1	E2	E3	E4	F	G	H	
											DIA.	QTY.
1/2	5.00	2.50	3.50	2.375	12.00	11.00	6.812	2.375	.622	1/2 – 150	.625	4
5/8	5.50	2.75	3.875	2.75	12.00	11.00	6.812	3.031	.824	3/4 – 150	.625	4
3/4	5.50	2.75	3.875	2.75	12.00	11.00	6.937	3.156	.824	3/4 – 150	.625	4
1	5.50	2.75	4.25	3.125	12.00	11.00	7.062	3.281	1.049	1 – 150	.625	4
1 1/4	6.00	3.00	4.625	3.50	12.20	11.33	7.187	3.406	1.38	1 1/4 – 150	.625	4
1 1/2	6.00	3.00	5.00	3.875	12.33	11.45	7.25	3.468	1.610	1 1/2 – 150	.625	4
2	6.50	3.25	6.00	4.75	12.56	11.69	7.625	3.843	2.067	2 – 150	.75	4
2 1/2	7.00	3.50	7.00	5.50	12.87	12.00	7.875	4.093	2.488	2 1/2 – 150	.75	4
3	10.00	5.00	7.50	6.00	13.13	12.25	8.000	4.218	3.068	3 – 150	.75	4
3 1/2	12.00	6.00	8.50	7.00	13.38	12.50	8.687	4.906	3.548	3 1/2 – 150	.75	8
4	12.00	6.00	9.00	7.50	13.63	12.75	8.75	4.968	4.062	4 – 150	.75	8
5	14.00	7.00	10.00	8.50	14.16	13.28	9.468	5.687	5.067	5 – 150	.875	8
6	14.00	7.00	11.00	9.50	14.69	13.80	9.937	6.156	6.065	6 – 150	.875	8
8	16.00	8.00	13.50	11.75	16.63	14.75	10.812	7.031	8.22	8 – 150	.875	8
10	20.00	10.00	16.00	14.25	16.75	15.88	11.875	8.093	10.062	10 – 150	1.00	12
12	24.00	12.00	19.00	17.00	17.75	16.88	12.625	8.843	12.062	12 – 150	1.00	12

REPLACES 500-0158

DRAWN	DW	SIZE	CAGE CODE	DWG NO	REV
CHECKED	JD	C	33321	HOX-5002	H
		SCALE NONE		SHEET 2 OF 6	

DWG NO.	HOX-5002	SH 3	REV G

REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APP

NOMINAL DIMENSIONS FOR FLOWMETERS WITH 300lb. FLANGES

SIZE	A	B	C	D	E1	E2	E3	E4	F	G	H	
											DIA.	QTY.
1/2	5.00	2.50	3.75	2.6285	12.00	11.00	6.812	2.375	.622	1/2 – 300	.625	4
5/8	5.50	2.75	4.625	3.25	12.00	11.00	6.812	3.031	.824	3/4 – 300	.75	4
3/4	5.50	2.75	4.625	3.25	12.00	11.00	6.937	3.156	.824	3/4 – 300	.75	4
1	5.50	2.75	4.875	3.50	12.00	11.00	7.062	3.281	1.049	1 – 300	.75	4
1 1/4	6.00	3.00	5.25	3.875	12.20	11.33	7.187	3.406	1.38	1 1/4 – 300	.75	4
1 1/2	6.00	3.00	6.125	4.50	12.33	11.45	7.25	3.468	1.610	1 1/2 – 300	.875	4
2	6.50	3.25	6.50	5.00	12.56	11.69	7.625	3.843	2.067	2 – 300	.75	8
2 1/2	7.00	3.50	7.50	5.875	12.87	12.00	7.875	4.093	2.488	2 1/2 – 300	.875	8
3	10.00	5.00	8.25	6.625	13.13	12.25	8.000	4.218	3.068	3 – 300	.875	8
3 1/2	12.00	6.00	9.00	7.25	13.38	12.50	8.687	4.906	3.548	3 1/2 – 300	.875	8
4	12.00	6.00	10.00	7.875	13.63	12.75	8.75	4.968	4.062	4 – 300	.875	8
5	14.00	7.00	11.00	9.25	14.16	13.28	9.468	5.687	5.067	5 – 300	.875	8
6	14.00	7.00	12.50	10.625	14.69	13.80	9.937	6.156	6.065	6 – 300	.875	8
8	16.00	8.00	15.00	13.00	16.63	14.75	10.812	7.031	8.22	8 – 300	1.00	8
10	20.00	10.00	17.50	15.25	16.75	15.88	11.875	8.093	10.062	10 – 300	1.125	16
12	24.00	12.00	20.50	17.75	17.75	16.88	12.625	8.843	12.062	12 – 300	1.125	16

REPLACES 500-0158

DRAWN	DW	SIZE	CAGE CODE	DWG NO	REV
CHECKED	JD	C	33321	HOX-5002	G
		SCALE NONE		SHEET 3 OF 6	

DWG NO.	HOX-5002	SH 4	REV H

REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APP

NOMINAL DIMENSIONS FOR FLOWMETERS WITH 400 & 600lb. FLANGES

SIZE	A	B	C	D	E1	E2	E3	E4	F	G	H	
											DIA.	QTY.
1/2	5.00	2.50	3.75	2.6285	12.00	11.00	6.812	2.375	.622	1/2 – 400/600	.625	4
5/8	5.50	2.75	4.625	3.25	12.00	11.00	6.812	3.031	.824	3/4 – 400/600	.75	4
3/4	5.50	2.75	4.625	3.25	12.00	11.00	6.937	3.156	.824	3/4 – 400/600	.75	4
1	5.50	2.75	4.875	3.50	12.00	11.00	7.062	3.281	1.049	1 – 400/600	.75	4
1 1/4	6.00	3.00	5.25	3.875	12.20	11.33	7.187	3.406	1.38	1 1/4 – 400/600	.75	4
1 1/2	6.00	3.00	6.125	4.50	12.33	11.45	7.25	3.468	1.610	1 1/2 – 400/600	.875	4
2	6.50	3.25	6.50	5.00	12.56	11.69	7.625	3.843	2.067	2 – 400/600	.75	8
2 1/2	7.00	3.50	7.50	5.875	12.87	12.00	7.875	4.093	2.488	2 1/2 – 400/600	.875	8
3	10.00	5.00	8.25	6.625	13.13	12.25	8.000	4.218	3.068	3 – 400/600	.875	8
3 1/2	12.00	6.00	9.00	7.25	13.38	12.50	8.687	4.906	3.548	3 1/2 – 400/600	1.00	8
4	12.00	6.00	10.75	8.50	13.63	12.75	8.75	4.968	4.062	4 – 400/600	1.00	8
5	14.00	7.00	13.00	10.50	14.16	13.28	9.468	5.687	5.067	5 – 400/600	1.125	8
6	14.00	7.00	14.00	11.50	14.69	13.80	9.937	6.156	6.065	6 – 400/600	1.125	12
8	16.00	8.00	16.50	13.75	16.63	14.75	10.812	7.031	8.22	8 – 400/600	1.25	12
10	20.00	10.00	20.00	17.00	16.75	15.88	11.875	8.093	10.062	10 – 400/600	1.375	16
12	24.00	12.00	22.00	19.25	17.75	16.88	12.625	8.843	12.062	12 – 400/600	1.375	20

REPLACES 500-0158

DRAWN	DW	SIZE	CAGE CODE	DWG NO	REV
CHECKED	JD	C	33321	HOX-5002	H
		SCALE NONE		SHEET 4 OF 6	

DWG NO.	HOX-5002	SH 5	REV H

REVISIONS

ZONE	REV	DESCRIPTION	DATE	APP

NOMINAL DIMENSIONS FOR FLOWMETERS WITH 900 & 1500lb. FLANGES

SIZE	A	B	C	D	E1	E2	E3	E4	F	G	H	
											DIA.	QTY.
1/2	7.00	3.50	4.75	3.25	12.00	11.00	6.812	2.375	.622	1/2 – 900/1500	.88	4
5/8	7.00	3.50	5.125	3.50	12.00	11.00	6.812	3.031	.824	3/4 – 900/1500	.88	4
3/4	7.00	3.50	5.125	3.50	12.00	11.00	6.937	3.156	.824	3/4 – 900/1500	.88	4
1	8.00	4.00	5.875	4.00	12.00	11.00	7.062	3.281	1.049	1 – 900/1500	1.00	4
1 1/4	8.00	4.00	6.25	4.375	12.20	11.33	7.187	3.406	1.38	1 1/4 – 900/1500	1.00	4
1 1/2	9.00	4.50	7.00	4.875	12.33	11.45	7.25	3.468	1.610	1 1/2 – 900/1500	1.12	4
2	9.00	4.50	8.50	6.50	12.56	11.69	7.625	3.843	2.067	2 – 900/1500	1.00	8
2 1/2	10.00	5.00	9.625	7.50	12.87	12.00	7.875	4.093	2.488	2 1/2 – 900/1500	1.12	8
3	10.00	5.00	9.50	7.50	13.13	12.25	8.000	4.218	3.068	3 – 900	1.00	8
3	10.00	5.00	10.50	8.00	13.13	12.25	8.000	4.218	3.068	3 – 1500	1.25	8
3 1/2	–	–	–	–	–	–	–	–	–	–	–	–
4	12.00	6.00	11.50	9.25	13.63	12.75	8.75	4.968	4.062	4 – 900	1.25	8
4	12.00	6.00	12.25	9.50	13.63	12.75	8.75	4.968	4.062	4 – 1500	1.38	8
5	14.00	7.00	13.75	11.00	14.16	13.28	9.468	5.687	5.067	5 – 900	1.38	8
5	14.00	7.00	14.75	11.50	14.16	13.28	9.468	5.687	5.067	5 – 1500	1.62	8
6	14.00	7.00	15.00	12.50	14.69	13.80	9.937	6.156	6.065	6 – 900	1.25	12
6	14.00	7.00	15.50	12.50	14.69	13.80	9.937	6.156	6.065	6 – 1500	1.50	12
8	16.00	8.00	18.50	15.50	16.63	14.75	10.812	7.031	8.22	8 – 900	1.50	12
8	16.00	8.00	19.00	15.50	16.63	14.75	10.812	7.031	8.22	8 – 1500	1.75	12
10	20.00	10.00	21.50	18.50	16.75	15.88	11.875	8.093	10.062	10 – 900	1.50	16
10	20.00	10.00	23.00	19.00	16.75	15.88	11.875	8.093	10.062	10 – 1500	2.00	12
12	24.00	12.00	24.00	21.00	17.75	16.88	12.625	8.843	12.062	12 – 900	1.50	20
12	24.00	12.00	26.50	22.50	17.75	16.88	12.625	8.843	12.062	12 – 1500	2.12	16

REPLACES 500-0158

DRAWN	DW	SIZE	CAGE CODE	DWG NO	REV
CHECKED	JD	C	33321	HOX-5002	H
		SCALE NONE		SHEET 5 OF 6	

DWG NO.	HOX-5002	SH 6	REV H

REVISIONS

ZONE	REV	DESCRIPTION	DATE	APP

NOMINAL DIMENSIONS FOR FLOWMETERS WITH 2500lb. FLANGES

SIZE	A	B	C	D	E1	E2	E3	E4	F	G	H	
											DIA.	QTY.
1/2	7.00	3.50	5.25	3.50	12.00	11.00	6.812	2.375	.622	1/2 – 2500	.875	4
5/8	7.00	3.50	5.50	3.75	12.00	11.00	6.812	3.031	.824	3/4 – 2500	.875	4
3/4	7.00	3.50	5.50	3.75	12.00	11.00	6.937	3.156	.824	3/4 – 2500	.875	4
1	8.00	4.00	6.25	4.25	12.00	11.00	7.062	3.281	1.049	1 – 2500	1.00	4
1 1/4	8.00	4.00	7.25	5.125	12.20	11.33	7.187	3.406	1.38	1 1/4 – 2500	1.125	4
1 1/2	9.00	4.50	8.00	5.75	12.33	11.45	7.25	3.468	1.610	1 1/2 – 2500	1.25	4
2	9.00	4.50	9.25	6.75	12.56	11.69	7.625	3.843	2.067	2 – 2500	1.125	8
2 1/2	10.00	5.00	10.50	7.75	12.87	12.00	7.875	4.093	2.488	2 1/2 – 2500	1.25	8
3	11.00	5.50	12.00	9.00	13.13	12.25	8.000	4.218	3.068	3 – 2500	1.375	8
3 1/2	–	–	–	–	–	–	–	–	–	–	–	–
4	12.00	6.00	14.00	10.75	13.63	12.75	8.75	4.968	4.062	4 – 2500	1.625	8
5	14.00	7.00	16.50	12.75	14.16	13.28	9.468	5.687	5.067	5 – 2500	1.875	8
6	16.00	8.00	19.00	14.50	14.69	13.80	9.937	6.156	6.065	6 – 2500	2.125	12
8	18.00	9.00	21.75	17.25	16.63	14.75	10.812	7.031	8.22	8 – 2500	2.125	12
10	22.00	11.00	26.50	21.25	16.75	15.88	11.875	8.093	10.062	10 – 2500	2.625	12
12	24.00	12.00	30.00	24.375	17.75	16.88	12.625	8.843	12.062	12 – 2500	2.875	12

REPLACES 500-0158

DRAWN	DW	SIZE	CAGE CODE	DWG NO	REV
CHECKED	JD	C	33321	HOX-5002	H
		SCALE NONE		SHEET 6 OF 6	

DWG NO.	PCX-901	SH 1	REV A

REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPD
	A	DWG NO WAS 500-0014, ADDED RF MC3PA COIL SPECIFICATIONS. (CS)	970519	

PICKUP COIL SPECIFICATIONS:

MODEL NOS. PC13-74G AND PC13-74S:
A STANDARD RELUCTANCE TYPE PICKUP COIL, OUR MOST POPULAR UNIVERSAL COIL USED ON FLOWMETERS, TACHOMETERS, PUMPS, GEARS AND A WIDE VARITY OF APPLICATIONS.

PC13-74G, PC13-110G, PC13-108G, PC13-74EX
- DC RESISTANCE: 1800 ±10%
- OVERALL LENGTH: 2 23/32" (WITHOUT TIP)
- INDUCTION: 1.3H ±10%
- GAUSS: 850 ±10%

PC13-74S
- DC RESISTANCE: 1850 ±15%
- OVERALL LENGTH: 2 23/32" (WITHOUT TIP)
- INDUCTION: 1.5H ±20%
- GAUSS: 700 ±20%

MODEL NO. PC13-70G:
OUR SMALLEST RELUCTANCE TYPE PICKUP COIL, THE SAME ELECTRICALLY AS THE PC13-74, EXCEPT THE PHYSICAL DIMENSIONS. USED ONLY WHERE WEIGHT AND SIZE ARE A FACTOR.

PC13-70G
- DC RESISTANCE: 1800 ±10%
- OVERALL LENGTH: 1 27/32" (WITHOUT TIP)
- INDUCTION: 1.4H ±10%
- GAUSS: 900 ±10%

MODEL NOS. PC24-45G AND PC24-45S:
A STANDARD RELUCTANCE, LOWER MAGNETIC DRAG TYPE PICKUP COIL USED ON SMALL DEVICES THAT ARE TO BE SENSED, OR ANYWHERE IT IS DESIRABLE TO HAVE A LESSER AMOUNT OF MAGNETIC INFLUENCE INDUCED UPON THE DEVICE BEING SENSED, THUS REDUCING ANY MAGNETIC DRAG. THIS COIL HAS AMPLE SIGNAL OUTPUT AND INCREASES THE RANGE ON SMALL FLOWMETERS, MICRO FLOWMETERS, AND OTHER SIMILAR DEVICES.

PC24-45G, PC24-115G, PC24-45EX, PC24-113G
- DC RESISTANCE: 1350 ±10%
- OVERALL LENGTH: 2 9/32" (WITHOUT TIP)
- INDUCTION: 1.7H ±10%
- GAUSS: 350 ±10%

PC24-45S
- DC RESISTANCE: 1850 ±15%
- OVERALL LENGTH: 2 9/32" (WITHOUT TIP)
- INDUCTION: 1.5H ±20%
- GAUSS: 250 ±20%

MODEL NOS. PC28-13G AND PC28-14G

PC28-13G
- DC RESISTANCE: 120 ±20%
- OVERALL LENGTH: 3.125" (WITHOUT TIP)
- HIGH DRAG

PC28-14G
- DC RESISTANCE: 180 ±20%
- OVERALL LENGTH: 3.125" (WITHOUT TIP)
- LOW DRAG

MODEL NO. MC3PA RF COIL
- DC COIL RESISTANCE: 12.0 OHMS ±10%
- COIL INDUCTANCE: 1 MILLIHENRY ±10%
- OPERATING TEMPERATURE: -325F TO +325F

PICKUP COIL PART NO. TO STOCK NO.	
PART NO.	STOCK NO.
PC13-70G	300-6014
PC13-74G	300-6003
PC13-74S	300-6004
PC24-45G	300-6005
PC24-45S	300-6006
PC28-13G	300-6008
PC28-14G	300-6011
PC13-110G	300-6002
PC13-108G	300-6017
PC24-115G	300-6019
PC24-45EX	300-6007
PC13-74EX	300-6022
PC24-113G	300-6020
MC3PA	300-6001



PICKUP COIL DIMENSIONS

	DIMENSION 'A'	DIMENSION 'B'
PC13-70G	1 27/32"	.562
PC13-74G	2 23/32	.562
PC24-45G	2 9/32	.562
PC24-113G	3 13/32	1.15
PC13-110G	2.695	.562
PC13-108G	1.975	.562



PICKUP COIL DIMENSIONS
PC13-74S
PC24-45S



PICKUP COIL WITH PIGTAIL

PC28-13G
PC28-14G



PICKUP COIL WITH PIGTAIL

PC24-45EX



RF PICKUP COIL DIMENSIONS

MC3PA

		MATERIAL	DRAWN SWEET	DATE 950821	HOFFER FLOW CONTROLS, INC ELIZABETH CITY, NC 27909
			CHECK J.DEFEO	950822	
			PRODUCTION M.K.VAUGHN	950822	
		FINISH	PROJ ENG KRH	950822	TITLE: PICKUP COIL SPECIFICATIONS
NEXT ASSY	USED ON				SIZE D / CAGE CODE 33321 / DWG NO PCX-901 / REV A
APPLICATION					SCALE N/A / SHEET 1 OF 1

CONFIDENTIAL PROPERTY OF HOFFER FLOW CONTROLS, INC. (HFC) NOT TO BE DISCLOSED TO OTHERS, REPRODUCED, OR USED FOR ANY OTHER PURPOSE, EXCEPT AS AUTHORIZED IN WRITING BY HFC. MUST BE RETURNED ON DEMAND, ON COMPLETION OF ORDER OR OTHER PURPOSE FOR WHICH LENT.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES OTHER THAN THE SIZE OF RAW MATERIAL SHALL BE HELD AS FOLLOWS:
2 PLACE DECIMALS ± .01
3 PLACE DECIMALS ± .005
FRACTIONAL ± 1/64
ANGULAR ± 1/2°

DWG NO. PCX-902 | SH 1 | REV –

REVISIONS

ZONE	REV	DESCRIPTION	DATE	APPD

SPECIFICATIONS:

RP–M SERIES:

VARIABLE RELUCTANCE (LOW MAGNETIC DRAG) TYPE PICKUP COIL WITH SELF–CONTAINED PREAMPLIFIER PROVIDING A CONDITIONED PULSE OUTPUT.

INPUT POWER: 8–30VDC, 10mA MAXIMUM @ NO LOAD
PULSE OUTPUT TYPES: TTL/CMOS
OPEN COLLECTOR – 400mA MAX. CURRENT
0–10VDC SQUARE WAVE

FREQUENCY RANGE: 2Hz TO 10kHz DEPENDING ON METER
GAUSS: 320±10%
OPERATING TEMPERATURE: –20°C TO 85°C
STORAGE TEMPERATURE: –65°C TO 150°C

RP–R SERIES:

MODULATED CARRIER (RF) TYPE PICKUP COIL WITH SELF–CONTAINED PREAMPLIFIER PROVIDING A CONDITIONED PULSE OUTPUT.

INPUT POWER: 8–30VDC, 10mA MAXIMUM @ NO LOAD
PULSE OUTPUT TYPES: TTL/CMOS
OPEN COLLECTOR – 400mA MAX. CURRENT
0–10VDC SQUARE WAVE

FREQUENCY RANGE: 2Hz TO 5kHz DEPENDING ON METER
OPERATING TEMPERATURE: –20°C TO 85°C
STORAGE TEMPERATURE: –65°C TO 150°C

PIN CONNECTIONS:

PIN 'A' (RED): INPUT POWER (+)
PIN 'B' (BLK): COMMON (–)
PIN 'C' (WHR): PULSE OUTPUT (+)



MAG. REDI–PULSE
WITH CONNECTOR



RF REDI–PULSE
WITH CONNECTOR



MAG. REDI–PULSE
POTTED



MAG. REDI–PULSE
NPT



RF REDI–PULSE
POTTED



RF REDI–PULSE
NPT

		MATERIAL	DRAWN	DATE
			CHECK	
			PROJ ENG	
		FINISH		
NEXT ASSY	USED ON			
APPLICATION				

CONFIDENTIAL PROPERTY OF HOFFER FLOW CONTROLS, INC. (HFC) NOT TO BE DISCLOSED TO OTHERS, REPRODUCED, OR USED FOR ANY OTHER PURPOSE, EXCEPT AS AUTHORIZED IN WRITING BY HFC. MUST BE RETURNED ON DEMAND, ON COMPLETION OF ORDER OR OTHER PURPOSE FOR WHICH LENT.

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES. TOLERANCES OTHER THAN THE SIZE OF RAW MATERIAL SHALL BE HELD AS FOLLOWS:
2 PLACE DECIMALS ± .01
3 PLACE DECIMALS ± .005
FRACTIONAL ± 1/64
ANGULAR ± 1/2°

HOFFER FLOW CONTROLS, INC
ELIZABETH CITY, NC 27909

TITLE: PICKUP COIL SPECIFICATIONS – REDI–PULSE

SIZE	CAGE CODE	DWG NO	REV
D	33321	PCX–902	–

SCALE N/A | SHEET 1 OF 1